

No. COM:LOE:VV:MYSEAM-2:BUILDING SAFTEY 2021-22

Sub: Manasarowar Pushkarini Vidyashrama's safety certificate to be issued.

Ref: 1. Requisition date: 18.10.2021

2. Assistant Executive Engineer, department of Public Works, No 1 Special Subdivision, Mysore Office Letter no 634, Date: 8.11.2021

In connection with the above letter of reference to the Assistant Engineer, department of Public Works, No 1 Special Subdivision, Mysore, Principal of Manasarowar Pushkarini Vidyashrama, Vijayanagar 2<sup>nd</sup> Stage, Mysore has requested to issue a certificate of safety of the school building. The details of the school building have been submitted in the prescribed format.

Manasarowar Pushkarini Vidyashrama School building at Vijayanagar 2<sup>nd</sup> Stage Mysore. Assistant Executive Engineer, Department of Public Works, No 1, Special Subdivision, Mysore and Education jointly inspected with the department officials and observed that the building is in good condition.

The building consists of 3 blocks, in 1<sup>st</sup> block ground floor + 3 floors, 2<sup>nd</sup> block ground + 2 floors, 3<sup>rd</sup> block ground + 2 floors. The building has ventilation with plenty of air and light. The building has an essential drinking water supply and sanitary amenities. The building has 3 staircases and CCTV camera is installed at the necessary places in the building.

Continuing with regard to the safety of the building, the Assistant Executive Engineer No 1, Special Subdivision, Mysore in the reference letter, regarding the concrete integrity of the building dated 27.10.2021 at Vidyavardhaka College of Engineering, Mysore, through non-destructive digital tester and physical observation accordingly necessary field tests have been conducted. An inspection report by the technical team with the consultant reported that the building was found to be in good condition, with the conclusion report provided by the firm as follows.

- Ultra-sonic Pulse Velocity Test

Conducting Ultrasonic Pulse Velocity Test for compressive strength in – situ concrete on columns, beams and slab at critical points using “Pundit 6” (Portable Ultra Sonic Non-Destructive Digital indicating tester). The inspection found the building to be of good quality.

Recognizance, visual inspection of building cracks, distress, dampness etc. test is carried out by Vidyavardhaka College of Engineering, Mysore along with the technical team of the Department of Public Works. The building is found to be of high quality.



Original Document Certificate  
I, Kannada translate it in English.  
and the translation Verified by me  
Notary Mysore City 31/05/2022

For MANASAROWAR PUSHKARINI VIDYASHRAMA  
Secretary

Attested  
31 MAY 2022  
PRINCIPAL  
MANASAROWAR PUSHKARINI VIDYASHRAMA  
VIJAYANAGAR. IInd STAGE  
MYSORE - 570 017

- C N Yadunandan, Principal Consultant, Yasha's Consultants, Mysore, has certified that the building was built and secured as per the National Building Code of India 2016.
- According to the National Building Code of India 2016, form for Certificate of Structural Design sufficiency was certified and issued by C N Yadunandan, Principal Consultant, Mysore.


All the documents provided by the institution were reviewed by Vidyaavardhaka College of Engineering, Mysore, who certified that the building was structurally safe, and the building was "structurally stable".

Because of the inspection reports that the building was "structurally stable" considering this the building has been issued with a certificate of safety for the current 5 years from 2021-22.

In continuation with this, Fire Safety Department is responsible for the building's fire safety certificate of the school building, subject to the conditions specified.

Yours sincerely

Executive Engineer  
Department of Public Works  
Special Division Works  
Mysore



The Original Document/Certificate  
in Kannada translated to English  
and the translation Verified by me  
*[Signature]*  
Notary, Mysore City

31/05/2022

31 MAY 2022

For MANASAROWAR PUSHKARINI  
VIDHYASHRAMA  
*[Signature]*  
SECRETARY

Attested  
*[Signature]*  
PRINCIPAL  
MANASAROWAR PUSHKARINI VIDHYASHRAMA  
VIJAYANAGAR, II<sup>nd</sup> STAGE  
MYSORE - 570 017